

# **CITY OF KINGMAN**

## **2012 ADDENDUM**

**TO THE**

## **MAG UNIFORM STANDARD**

## **SPECIFICATIONS**

## **FOR PUBLIC WORKS CONSTRUCTION**

**CITY OF KINGMAN**  
ENGINEERING DEPARTMENT  
310 NORTH 4<sup>TH</sup> STREET  
KINGMAN, AZ 86401  
PHONE (928) 753-8122  
FAX (928) 753-8118  
[www.cityofkingman.gov](http://www.cityofkingman.gov)

THE FOLLOWING ADDITIONS, DELETIONS, AND/OR MODIFICATIONS ARE MADE TO THE UNIFORM STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION SPONSORED AND DISTRIBUTED BY THE MARICOPA ASSOCIATION OF GOVERNMENTS, AS APPLICABLE TO PUBLIC WORKS CONSTRUCTION IN THE CITY OF KINGMAN, ARIZONA, AND FOR WATER AND SEWERAGE PROJECTS LOCATED WITHIN THE CITY'S WATER AND SEWERAGE SYSTEM SERVICE AREA.

**CITY OF KINGMAN**  
**2012 ADDENDUM TO MAG STANDARD SPECIFICATIONS**

---

**SECTION 105.6** (revised 2004) *Add the following at the end of the first sentence of the seventh paragraph*

“and except as required under the following conditions”

whenever the development causes water meter boxes, water valve boxes, sewer manholes, sewer cleanouts, or fire hydrants to be out of compliance with applicable City Specifications and Details, then the expense of the relocation or adjustment shall be borne by the Developer; the relocation or adjustment shall be in accordance with the applicable City Specifications and Details.

**SECTION 105.8** (revised 2004)

**Section 301.3** (revised 2010) *Add the following:*

Minimum frequency for SubGrade compaction test:

Street Section: shall be a minimum of one per lift per 500ft per 12’ span

Curb/Gutter/Sidewalk: minimum of one per lift per 500ft.

Sidewalk ramp. Driveway & Alley entrance: Minimum of one per lift, per ramp, driveway or alley entrance.

\*Additional tests may be required as deemed necessary by the City of Kingman Engineering Representative.

**Section 310.1** (revised 2010) *Add the following:*

Minimum frequency of Compaction Tests for Aggregate base course:

Street Section: shall be a minimum of one test per lift per 500ft per 12’ span.

Curb/Gutter/Sidewalk: minimum of one per lift per 500ft.

Sidewalk ramp. Driveway & Alley entrance: Minimum of one per lift, per ramp, driveway or alley entrance.

\*Additional tests may be required as deemed necessary by the City of Kingman Engineering Representative.

**SECTION 321.10.3** (revised 2004) (2004 section No. 321.5.4 revised to 321.10.3 per 2010 mag) *Surface Testing:*

Add the following to Paragraph 2: The water testing of streets requirement may be waived by the Engineer or his designated representative if acceptable drainage patterns are evident.

**Section 321.10.5** (revised 2010) *Add the following:*

Density verification by the nuclear method is acceptable for pavement matching and surface replacement over pipe trenches etc. and as specified by the City of Kingman Engineering Representative. Core holes shall be patched with hot mix or other approved material.

**CITY OF KINGMAN**  
**2012 ADDENDUM TO MAG STANDARD SPECIFICATIONS**

---

**SECTION 336.2.2** (revised 2010) *Modify wording:*

Where existing asphalt has to be removed for any construction or repairs, the existing asphalt shall be cut back far enough to remove any asphalt edge damaged by construction and shall not be less than two feet wide. The length of the cut shall be sufficient enough to encompass asphalt that was disturbed by construction activities as directed by the City of Kingman Engineering Representative.

**SECTION 336.2.4.1** (revised 2010) *Modify wording of third paragraph:*

Pavement replacement for all pavement cuts including trenches and pot holes shall be per City of Kingman Standard Detail 200-1. All pavement patches shall be compacted with a vibratory steel wheel roller to the same density specified for asphalt concrete pavement.

**SECTION 336.3** (revised 2010)

Eliminates T-Top Asphalt Replacement

**Section 340.2.1** (revised 2012) *Add to last sentence:*

Allowable materials shall be Cast in Place Wet Set design & yellow in color unless approved otherwise by the city engineer. All detectable warnings shall be authorized for use by the City of Kingman Engineering Representative prior to installation.

**SECTION 340.3** (revised 2010) *Modify to specify expansion joint spacing and concrete finish:*

Contraction and Expansion joint spacing for curb and sidewalk shall be per City of Kingman Standard Detail 230. The finish of all concrete shall be smooth, straight and defect free, this includes but not limited to cracks, chips and broken edges.

**SECTION 340.5** (revised 2012) Add to end of 2<sup>nd</sup> paragraph.

Payment for Curb Ramp Radial installations shall be all areas between the E.C.R. and B.C.R. including curb & gutter.

**CITY OF KINGMAN STANDARD SPECIFICATION**  
**SECTION 400**  
**SURVEYING STANDARDS**

**SECTION 400** (revised 2004)

City of Kingman Specifications Section 400-Surveying Standards is added.

**SECTION 400.1** (revised 2004) *General*

All public works improvements and new subdivision developments requiring construction or land surveying shall conform to the standards set forth herein.

**CITY OF KINGMAN**  
**2012 ADDENDUM TO MAG STANDARD SPECIFICATIONS**

---

**SECTION 400.2** (revised 2004) *Public Works Improvements under city contract:*

The City Surveyor shall survey and set construction stakes on improvements made under contract with the City of Kingman, unless otherwise stipulated in the contract.

**SECTION 400.3** (revised 2010) *Add temporary lot corner staking to end of paragraph:*

On all public works improvement projects installed under private contract, it shall be the responsibility of the contractor to obtain, at his expense, the services of a professional engineer or land surveyor, registered in the State of Arizona, to survey and stake the project. Temporary staking of lot corners shall be furnished by a registered land surveyor licensed to practice in the state of Arizona and shall be placed prior to the start of construction.

**SECTION 400.4** (revised 2004) *Preservation of survey monuments and bench marks:*

The contractor shall notify the City land surveyor at least seven (7) days before starting work, in order that the City engineer or land surveyor may take necessary measures to ensure the preservation of survey monuments and bench marks.

The contractor shall not disturb permanent survey monuments or bench marks without the consent of the City Surveyor, and shall bear the expense of replacing any that may be disturbed without permission. Replacement shall be done by the City Surveyor.

When a change is made in the finished elevation of the pavement of any roadway in which a permanent survey monument is located, the contractor shall adjust the monument cover to the new grade unless otherwise specified by the City Surveyor.

The contractor shall preserve property line and corner survey markers, except where their destruction is unavoidable. Markers that are lost or disturbed shall be replaced at the contractor's expense by a land surveyor registered by the State of Arizona.

**SECTION 400.5** (revised 2004) *Construction stakes preservation:*

The contractor shall preserve construction survey stakes and marks for the duration of their usefulness. If any construction survey stakes are lost or disturbed and need to be replaced, such replacement shall be done by a civil engineer or land surveyor registered by the State of Arizona.

**SECTION 400.6** (revised 2004) *Interval for construction stake of curbs, gutters, pavement blue tops, storm drains, sewers, etc.*

Construction staking shall conform to the following intervals, unless otherwise approved by the City Engineer:

LOCATION	INTERVAL FOR RATE		
	Under 0.5%	0.5%-3%	3%+
On Tangent	12.5'	25'	50'
On Curve, 50'to 150' Radius	12.5'	12.5'	12.5'

**CITY OF KINGMAN**  
**2012 ADDENDUM TO MAG STANDARD SPECIFICATIONS**

---

On Curve, 150'to 500' Radius	12.5'	20'	20'
On Curve, Over 500' Radius	12.5'	25'	25'

Curves will be divided into equal parts between Beginning of Curve and End of Curve or Grade Changes. Intervals refer to arc distance, in feet, on long side of concentric curves and are maximum limits.

**SECTION 400.7** (revised 2010) *Revise sentence:*

Elevations shall be based on the City of Kingman Bench Level Datum (NAVD29)

**SECTION 400.8** (revised 2012) *Add to paragraph:*

Alignment and elevation stakes shall be furnished by the contractor at set intervals and agreed upon offsets and stationing. Grade sheets shall include stationing, existing grade, design grade, cut or fill, off sets and Bench Mark used, with description. The contractor at his expense shall have his engineer or surveyor verify in writing that design grades are correct before placing asphalt, curb / gutter, sidewalk or any feature that requires grade or alignment controls. On water main projects, elevation stakes will be furnished when deemed necessary be the City of Kingman Engineer. Grade Sheets shall be complete and submitted prior to the start of construction. Grade sheets must have the Engineer or Surveyors company name and name of field personnel.

Prior to paving, the contractor shall locate all new and existing water and sewer main fixtures that will need to be brought to surface. This includes but is not limited to water valves, flush valves, manholes and cleanouts. As approved by the city engineer the contractor shall use G.P.S, conventional survey equipment or manual ties. The contractor shall provide field notes, project coordinates or tie sheets to the city engineer. All locates shall be on the center of the fixture and have a horizontal error of 0.50 (5ths of an inch) or less.

**SECTION 400.8.1** (revised 2010) *ADD: As-built / Record plans or drawings:*

Prior to final acceptance, As-Built / Record Drawings and a Point File in common interchange format (contains ASCII – American Standard Code for Information Interchange, with CSV – Comma Separated Values) shall be furnished to the City Engineering Department.

**SECTION 400.9** (revised 2010) *Modify subsection (12) omitting survey assurance requirement:*

The applicant/developer of a new subdivision shall have a registered land surveyor, licensed to practice in the State of Arizona, place permanent reference monuments in the subdivision as required herein.

- (l) Permanent Monuments shall be either:
  - a. Iron pipe not less than three quarter (3/4) inch in diameter and not less than twenty-two (22) inches in length with (RLS) identification attached.

**CITY OF KINGMAN**  
**2012 ADDENDUM TO MAG STANDARD SPECIFICATIONS**

---

- b. Nail and tag (RLS) set in lead.
  - c. Rebar not less than one-half (1/2) inch in diameter and not less than twenty-four (24) inches in length with (RLS) identification.
  - d. Large spike and washer stamped with (RLS) identification.
  - e. Concrete monument not less than six (6) inches in diameter and not less than eight (8) inches in length with metal disc stamped with (RLS) identification properly attached thereto and set flush with finished surface of paved street.
- (2) Permanent monuments shall be set on the tract boundary at the following locations:
- a. At all angle points
  - b. At intersection of street limits (R/W)
  - c. At intersection of City boundary
  - d. At distances on tangent not to exceed one-thousand (1000) feet
  - e. At intervisible points on tangent
  - f. At intersection of street or alley center lines
  - g. At intersection of Section lines
- (3) Permanent monuments shall be Type e as shown in Section 400.9 (1) and shall be set on street or alley center lines at the following locations:
- a. At P.I.'s or sub P.I.'s within street limits (R/W)
  - b. At P.C.'s, P.T.'s and intervisible chord points where P.I. is not accessible
  - c. At street and alley center line intersections
  - d. At street and alley center line intersections with City boundary.
- (4) Ties to Geodetic and section survey monuments will be made as follows:
- a. Direct ties shall be made to all Geodetic and Section survey monuments within the tract.
  - b. When no monument exists within a tract, ties shall be made to two (2) or more monuments outside the tract boundary within the quarter section.
  - c. When any Geodetic or Section monument is to be removed by construction of tract, the City surveyor's office shall be notified not less than thirty (30) days in advance of the removal date.
  - d. If Geodetic or Section monuments are shown on the subdivision plat by

**CITY OF KINGMAN**  
**2012 ADDENDUM TO MAG STANDARD SPECIFICATIONS**

---

bearing and distance, tie sheets for these monuments are required.

(5) Existing referenced monuments:

Monuments shall be set and tied out if located one-hundred (100) feet or more from previously tied out point.

(6) Tie points shall be in the form of:

- a. Lead and tack (L&T)
- b. Spike and tin (S&T)
- c. Any exceptions to use other tie points must be approved by the City Engineer.

(7) The number per point tied shall be:

- a. No less than three (3) tie points for each point referenced.
- b. Tie points shall be kept within the street limits (R/W)
- c. Two of the three tie points shall be on the center line or tract line produced or
- d. If P.I. falls within the street limit (R/W) and the tangent distance does not exceed one-hundred (100) feet, it is not necessary to tie out the P.S. or P.T. if the P.I. is tied out.
- e. Measured angles shall be shown at all P.I.'s, intersections and to all tie points set.

(8) Lead and tack ties shall be used as example, but not limited to the following locations:

- a. Sound rock dykes or ledges
- b. Large deeply embedded boulders
- c. Mortar laid masonry
- d. Concrete curbs and walks
- e. Concrete catch basins, bridges, head walls or any permanent concrete structure.

(9) Spike and tin ties shall be used as example, but not limited to the following locations:

- a. Trees and poles
- b. Sound wooden fence posts

**CITY OF KINGMAN**  
**2012 ADDENDUM TO MAG STANDARD SPECIFICATIONS**

---

- c. Asphalt pavement
- (10) Tie Notes Procedure shall be as follows:
- a. Only one point or street intersection shall be shown on a record sheet.
  - b. Notes shall conform to the furnished example plates obtainable from the City surveyor's office:
    - i. Title - Plate 1
    - ii. Tract boundary and/or City boundary with street center line - Plate 3
    - iii. Street center line intersection - Plates 2 and 4
    - iv. P.I.'s, P.C.'s, P.T.'s, P.C.C.'s and chord points - Plates 5, 6 and 7
    - v. Tie lines to Geodetic and Section monuments - Plates 8 and 9
  - c. All completed tie sheets shall be submitted to the City of Kingman Engineering Department. They will be filed there as a permanent record.
  - d. Show street widths, center line point to point distances and center line curve data.
  - e. Notes on any street shall be kept on consecutive pages and properly referenced from one page to another.
- (11) Tie Notes shall be on a standard sheet as follows:
- a. The notes shall be on quadrille rules loose leaf sheets (8 1/2" x 11") punched for a three-ring binder
  - b. North arrow to be shown on each tie sheet
  - c. Every effort shall be made to keep north to the top of the sheet
  - d. All tie sheets to be signed, sealed, and dated per A.R.S. 32-125
- (12) Lot Corners:
- All lot corners shall be monumented by a registered land surveyor licensed to practice in the State of Arizona, and shall be completed prior to recordation of the final plat. Lot monuments may be three-quarter (3/4) inch iron pipes, five-eighths (5/8) inch rebars, one-half (1/2) inch rebars or equal.

**CITY OF KINGMAN**  
**2012 ADDENDUM TO MAG STANDARD SPECIFICATIONS**

---

**SECTION 400.10** (Revised 2004) *Survey accuracy (excepting construction surveys)*

Survey accuracy shall conform to the following specifications:

- (1) Minimum of 1/20,000 in distance and direction

This specification to apply to: Section lines, Tract boundaries, core areas of the City or where zoning regulations permit zero set-backs and other high risk areas where property line locations are critical.

- (2) Minimum of 1/15,000 in distance and direction

This specification to apply to: Street center lines, Block boundaries in residential areas of the City where the intensity of use does not exceed about six dwelling units to the acre, shopping centers or malls and such other less critical or lower risk areas where zoning regulations do not permit major structures or buildings to be built on the property lines.

- (3) Minimum of 1/10,000 in distance and direction

This specification to apply to: Rural areas in the City where land may be used for recreation, park or other such uses, where the residential lot is one acre or larger and shall be restricted from further subdivision.

- (4) Application of the above criteria shall not operate to impose an error of measurement discrepancy which is no more than 0.03 feet between sequential monuments.

**SECTION 400.11** (revised 2004) *Permit revocation, penalty:*

In addition to any penalty imposed by law, any person violating any provision of this article shall have his permit revoked, and during the period of revocation no new permit shall be issued to such person until the violation is corrected to the satisfaction of the City Engineer. In the case where a contractor has disturbed permanent survey monuments or bench marks without written consent of the City Surveyor resulting in the replacement of the permanent survey monument or bench mark by City forces, the contractor shall reimburse the City for the cost of the replacement upon presentation of the cost figure by the City.

**SECTION 405** (revised 2004)

Sections 405.1 through 405.5 are deleted; refer to City of Kingman Specification No. 400-Surveying.

## CITY OF KINGMAN 2012 ADDENDUM TO MAG STANDARD SPECIFICATIONS

---

**SECTION 601.4.3** (revised 2010) *Add New Table:*

Minimum testing requirements for Aggregate backfill for Structure, trench backfill, pipe bedding and shade:

Proctor – sample point at stockpile – one per source

P.I. – sample point at stockpile – one per source

Gradation – sample point at stockpile – 1 per 500cy per source.

\*Additional tests may be required as deemed necessary by the City of Kingman Engineering Representative.

**SECTION 601.4.4** (revised 2010) *Add New Table:*

Minimum frequency for compaction testing of trench backfill includes water / sewer mains, service lines, telephone, gas, electric, cable tv or other utilities or appurtenance.

Parallel to street centerline: Minimum of one per lift per 500ft

Perpendicular to street centerline: Minimum one per lift per crossing.

\*Additional tests may be required as deemed necessary by the City of Kingman Engineering Representative.

**SECTION 601.4.5** (revised 2012) *Delete: use of water consolidation as a means of achieving Compaction.*

"Mechanical compaction in accordance with this section shall be performed to achieve desired compaction in all locations where Backfill Type I, II or II is required per Table 601.2.

**SECTION 610.3** (revised 2010) *Add text concerning unacceptable ultraviolet exposure:*

Polyvinyl chloride pressure pipe showing signs of physical damage or unacceptable ultraviolet exposure, as determined through visual inspection by the City of Kingman Engineering Representative, may be rejected. Pipe stored outside, and exposed to sunlight for more than thirty (30) days shall be covered with an opaque material such as canvas. Clear plastic sheets shall not be used for pipe cover. Air circulation shall be provided under the covering.

**SECTION 610.3.1** (added 2012)

Water line materials containing Brass or Bronze must comply with the current NSF 61 Standards at the time the project begins.

**SECTION 610.4** (revised 2012) *Add to last paragraph:*

Any vertical deflection of 22 ½ degrees or more will require ductile iron with approved joint restraints per Mag Standard Details 302-1, 302-2, 303-1 and 303-2 unless specified otherwise in the special provisions, plans or by the City Engineer.

Repair Sleeves/Couplers or any line coupling or splice fitting shall not be used unless approved otherwise the City Engineer.

Pipe bevels shall be removed when required at fittings, valves, fire hydrants and related

**CITY OF KINGMAN**  
**2012 ADDENDUM TO MAG STANDARD SPECIFICATIONS**

---

appurtenances and the pipe marked so proper depth of pipe insertion can be verified.

**SECTION 610.5.5** (revised 2012) delete both notes in paragraph allowing concrete encasement,

And add to end of paragraph:

Concrete encasement as a means of extra protection will not be allowed unless approved otherwise by the city engineer.

**SECTION 610.11** (revised 2004)

When plans call for connections from a new water main to an existing water meter, the work shall include new polyethylene (PE) or schedule 80 PVC pipe for services up to 2" per City of Kingman Standard Detail 344-1. Restrained ductile iron pipe will be used for 3-inch and larger service lines. PE pipe shall be iron pipe I.D. 200 psi, meeting M.A.G. 755. Residential meters and boxes shall be set parallel to the street centerline and to the finish grades and locations specified in the special provisions, plans or at the direction of the City of Kingman Engineering Representative.

**SECTION 610.12** (revised 2010) *Fire Service Line Connections – Add wording:*

It is the contractor's responsibility to coordinate onsite construction requirements, testing and inspections with the Fire Department that has jurisdictional authority over the project.

**SECTION 610.15** (revised 2012) *Modify wording for pressure test:*

All new lines and fittings shall be pressure tested against new valves unless approved otherwise by the City Engineer.

Acceptance pressure and leakage testing of new water mains shall be made AFTER subgrade preparation is completed and all utilities have been installed within the right-of-way.

Contractor shall provide gauges used for pressure testing. Gauges shall be used with a range based on test pressure putting the indication approximately mid-span. Any gauges deemed defective or inaccurate by the City of Kingman Engineering Representative shall be replaced by an acceptable gauge at the contractor's expense.

Hydrostatic pressure and leakage testing for all water mains and appurtenances including Ductile Iron Pipe shall be per applicable portions of M.A.G. Spec. 610.15 or as modified herein and shall be performed concurrently for a minimum of 2 hours or as directed by the City of Kingman Engineering Representative. Allowable leakage for will be in U.S. Gallons per hour.

**ND√P**

Formula:  $L = \frac{\dots\dots\dots}{7400}$

Where:

L = testing allowance (makeup water) in gallons per hour

N = Number of joints being tested

D = Nominal diameter of pipe in inches

**CITY OF KINGMAN**  
**2012 ADDENDUM TO MAG STANDARD SPECIFICATIONS**

---

P = Average observed test pressure of the pipe measured at the lowest end of test section shall be a minimum of 200 psi for lines smaller than 16 inches and 150 for lines 16 inches or larger unless specified otherwise in the special provisions, plans or by the City of Kingman Engineering Representative.

**SECTION 611.7** (revised 2010) – *Modify section to specify disinfection process:*

A mixture of Sodium Hypochlorite and water shall be used for the disinfection of water mains and associated appurtenances per ADEQ Engineering Bulletin No. 8. Any other method must be approved by the City of Kingman Engineering Representative.

**SECTION 611.8** (revised 2010) – *Modify existing section concerning introduction of chlorine into water systems:*

The mixture of water and sodium hypochlorite shall only be introduced into the water main, fire hydrants, fire service lines or associated appurtenances by a method and concentration that is approved by the City of Kingman Engineering Representative.

**SECTION 611.10** (revised 2010) – *Rewrite paragraph to reflect chlorination process:*

The initial chlorine content shall be measured and authorized for use by a City of Kingman Engineering representative before introduction into the line. The Minimum residual chlorine content after 24 hours shall be no less than 50ppm. Maximum chlorine concentration shall not exceed 150ppm in any part of the line. Chlorinating agent retention period shall not exceed 72 hours.

**SECTION 611.15** (revised 2010) *Revise 3<sup>rd</sup> paragraph to specify Bac-T sample frequency:*

Sample frequency shall be one per 1000ft with one minimum or as determined by the City of Kingman Engineering Representative.

**SECTION 615.6** (revised 2004) *Sanitary Sewer Service Taps:*

**Section 615.6.1** (revised 2004) *Add Repair/Replacement of Existing Sewer Service Lines:*

A plumber or contractor wishing to make a repair or replacement of an existing sewer service line must first obtain a City Right-of-Way permit and Sewer Tap permit (if applicable) and pay all appropriate fees. 48 hours advance notification to the Public Works Inspection Department is required prior to actual construction.

The contractor must then expose the existing service line to the sewer main to determine the condition of the existing line and tap. If the existing tap is usable per current City and UPC standards. The contractor has the option of utilizing the existing tap or installing a new service tap, which will require a Sewer tap permit. If a new tap is made, the old tap must then be capped or plugged at the sewer main by an acceptable method such as a VCP cap, plug and epoxy, grout, or concrete encasement.

**SECTION 615.10** (revised 2004) *Testing:*

**CITY OF KINGMAN**  
**2012 ADDENDUM TO MAG STANDARD SPECIFICATIONS**

---

Acceptance testing of new sewer lines shall be made AFTER subgrade preparation is completed and all utilities have been installed within the right-of-way.

**SECTION 615.11 (A) (6)** (revised 2010) *Add pressure gauge specification to note 6:*

Contractor shall provide gauges used for pressure testing. Gauges shall be used with a range based on test pressure putting the indication approximately mid-span. Any gauges deemed defective or inaccurate by the City of Kingman Engineering Representative shall be replaced by an acceptable gauge at the contractor's expense.

**SECTION 615.11 (A) (7)** (revised 2010) *Replace note 7 with low pressure air specification:*

Low Pressure Air Acceptance testing will be per ASTM F-1417-92, (2005) or latest revision.

**Section 615.11 (D)** (revised 2010) *Revise paragraph specifying closed circuit camera inspection of sewer:*

All new sewer mains shall have the interior visually inspected prior to paving using a remote closed circuit camera. The city will provide closed circuit camera service with the contractor's cooperation. The contractor shall coordinate with the City of Kingman Waste Water Superintendent to schedule closed circuit camera inspections. The contractor shall make manholes and cleanouts accessible and safe for the cities waste water crew and run water through the main prior to the interior inspection to the extent deemed necessary by the City of Kingman Waste Water Superintendent. If the contractor fails to schedule or cooperate with the city and or paving is already completed, the contractor will provide closed circuit camera inspection with DVD or VHS documentation at no cost to the city. Any defect in the pipe or construction methods revealed by the closed circuit camera inspection that's deemed unacceptable to the waste water superintendent shall be corrected by the contractor at no additional cost to the City of Kingman. This includes but not limited to bellies in the main indicated by standing water, dirt & debris, lips at joints, shifted connections at couplers or unacceptable service line connections at the main.

**Section 615.11 (E)** (revised 2010) *Add lamp lighting or remote camera testing requirement.*

All sewer line shall be tested for uniform slope by lamp lighting or remote camera per Arizona Administrative Code R18-9-E301.4.01. In the event remote camera services are not available, the engineer of record or his designee will conduct the lamp lighting test at no cost to the city.

**SECTION 625.1.1** (revised 2010) *Revise to include concrete collars as part of construction:*

Sewer Manholes: Construction shall consist of furnishing all materials and constructing manholes complete in place and set to finish grade as detailed including foundations walls, manhole frames, and covers, concrete collars, grouting the interior, and any incidentals thereto, at locations shown on the plans.

**CITY OF KINGMAN**  
**2012 ADDENDUM TO MAG STANDARD SPECIFICATIONS**

---

**SECTION 625.3.1** (revised 2010) *Add to the end of section addressing cracked concrete, Testing of manholes and approved interior coatings*

Concrete collars for frame and cover, cleanout frames and manhole bases shall be free of cracks and other defects and shall be replaced at no expense to the City before acceptance.

**SECTION 625.5** (revised 2010) *Revise first paragraph addressing concrete collars/finish grade*

Payment will be made at the unit price bid for each manhole, and shall be compensation in full for furnishing and installing manhole with frame and cover set to finish grade, complete with formed invert, concrete foundation, ladder rungs, cast iron frame and cover, concrete collar, excavation and backfill, paving cut replacement in excess of the applicable pay widths authorized in section 336, and any incidentals thereto in conformance with the plans and specifications.

**SECTION 630.4** (revised 2004) *Delete paragraph 3 and add the following:*

The City of Kingman only taps water mains for service connections. Wet taps to water mains for lines other than service connections shall be made by the Contractor. The Contractor making the tap must be approved by the City of Kingman Public Works Department prior to beginning any work.

**SECTION 631.1** (revised 2004) *Delete – covered in 2010 addendum 610.11*

**SECTION 631.2** (revised 2004) *First Paragraph*

Polyethylene pipe (iron pipe size I.D., 200 psi), shall conform with Section 755. (deletes "copper pipe, tubing and fittings shall conform with Section 754")

**SECTION 631.3.3** (revised 2004) *First Sentence:*

Revise to read: "The minimum depth of service pipe shall be as shown in the City of Kingman Detail No. 344-1."

**SECTION 631.3.5** (revised 2004) *First Paragraph:*

One inch and 3/4 inch service taps to new water mains may be made with a saddle. (deletes "tapped coupling or direct tap in accordance with the following provisions:")

**Section 702.** Revised 2010) *Add table:*

Minimum testing requirements for Aggregate Base:

Proctor-sample at stockpile – 1 sample per source

Gradation – sample at stockpile – 1 sample per 2000 T- 1 min.

P.I. – sample at stockpile – 1 sample per 2000 T – 1 min.

Fractured Faces- sample at stockpile – 1 per 2000 T – 1 min.

Abrasion – Sample at source – 1 sample min.

**CITY OF KINGMAN**  
**2012 ADDENDUM TO MAG STANDARD SPECIFICATIONS**

---

**SECTION 743.5** (revised 2004) *Vitrified Clay Pipe, Joints:*

Flexible compression couplings for plain end pipe will be allowed only at repair locations, points of connection to existing lines, and at sewer stub-outs (COK Detail 443). Flexible compression couplings shall be encased in concrete for a minimum of 1 foot on each side of the joint; the depth of encasement shall be a minimum of 6-inches around the complete diameter of the pipe.

**SECTION 750.2** (revised 2010) *(remove blue color requirement from this paragraph)*

Add the following paragraph: "All ductile iron pipe shall be encased in polyethylene in accordance with AWWA C-105/ANSI A21.5. Polyethylene shall be 8 mil minimum thickness and tubular collapsed folded or accordion type. Polyethylene shall be secured to the pipe with water proof tape at approximately 2 foot intervals."

**SECTION 750.3** (revised 2010) *Add acceptable restrained joint gasket for DIP:*

Acceptable restrained joint gasket for Ductile Iron Pipe is: Field Lok 350 Gasket manufactured by U.S. Pipe. All restrained joint fittings must be approved prior to use.

**CITY OF KINGMAN STANDARD SPECIFICATION**  
**SECTION 751**  
**POLYVINYL CHLORIDE (PVC) WATER PIPE AND FITTINGS**

**SECTION 751** (revised 2004) City of Kingman Specification 751 covering the use of PVC water pipe is added.

**SECTION 751.1** (revised 2004) *General:*

These specifications cover polyvinyl chloride (PVC) pressure pipe for use in supply lines and distribution systems that carry water under pressure. All PVC water pipe shall bear the National Sanitation Foundation (NSF) Seal for use with potable water.

**SECTION 751.2** (revised 2010) *Modify to reflect 2007AWWA Standards for new pressure classes for PVC Pipe:*

PVC pipe shall be manufactured and tested in accordance with the latest revision of AWWA C-900 or AWWA C-905, except as modified herein, for pipe intended for use in water service at maximum operating pressure of 165, 235, or 305 respectively for AWWA C-900, and operating pressures of 100, 125, 160, 165, 200, 235 for AWWA C-905, for the corresponding maximum operating pressures, unless shown otherwise on the plans or specified in the special provisions the minimum acceptable shall be class 235 for AWWA C-900 and Class 235 for AWWA C-905. Only pipe with Cast Iron Pipe Equivalent outside diameter will be allowed.

**SECTION 751.3** (revised 2004) *Materials:*

**CITY OF KINGMAN**  
**2012 ADDENDUM TO MAG STANDARD SPECIFICATIONS**

---

**SECTION 751.3.1** (revised 2004) *Pipe:*

Pipe shall be manufactured from Class 12454-A or Class 12454-B polyvinyl chloride.

**SECTION 751.3.2** (revised 2004) *Gaskets:*

Rubber gaskets shall be manufactured from a synthetic elastomer and shall comply in all respects with the physical requirements specified in ASTM F-477.

**SECTION 751.3.3** (revised 2004) *Lubricant:*

The lubricant used for assembly shall be compatible with the gaskets and the pipe materials and shall not support bacteria growth or otherwise affect potable qualities of the water.

**SECTION 751.4** (revised 2004) *Joining Systems:*

Joints for the piping system and fittings shall consist of an integral bell gasketed joint designed so that when assembled, the elastomeric gasket located within the bell is compressed radially on the pipe or fitting spigot to form a positive seal. The joint shall be designed to prevent displacement of the gasket from the joint during assembly and when in service. Solvent weld joints will not be allowed. The joint assembly shall meet laboratory performance requirements specified in ASTM D-3139. All pipe shall have a home mark on the spigot to indicate proper penetration when the joint is made. Deflection of joints and longitudinal bending shall be no more than half the maximum recommended by the manufacturer.

**SECTION 751.5** (revised 2004) *Fittings:*

**SECTION 751.5.1** (revised 2004) *Pipe Fittings:*

Fittings shall be cast (gray) iron or ductile iron and conform to AWWA C-110 or C-153 for 250 psi minimum working pressure rating cast on fittings. Fittings to be mechanical joint conforming to the above specifications. All fittings shall be cement lined in accordance with AWWA C-104.

**SECTION 751.5.2:** (revised 2004) *Service Connection Fittings:*

Taps to PVC pipe shall be made with rigid, full circle, wide body bronze clamps made specifically for use on AWWA C-900 SDR 18, PVC pipes. Service connections to AWWA C-905 PVC pipe are not allowed unless approved by the Utilities Superintendent.

**SECTION 751.6** (revised 2004) *Excavation, preparation of trench and backfilling:*

All trenches shall comply with the requirements for trench excavation, backfilling and compaction, per Section 601 of these standard specifications. Bedding and backfill material shall conform to City of Kingman Detail No. 392 or 400.

**CITY OF KINGMAN**  
**2012 ADDENDUM TO MAG STANDARD SPECIFICATIONS**

---

**SECTION 751.7** (revised 2004) *Preparation of trench bottom:*

The trench bottom must be shaped to provide continuous contact with the pipe. Whenever boulders, rocks or ledge rock are encountered, the trench shall be excavated as heretofore specified and the trench bottom backfilled and compacted with select granular material.

**SECTION 751.8** (revised 2004) *Joining of Pipe:*

Such assembly will be made in accordance with the manufacturer's recommendations. Each length of pipe and fitting shall be thoroughly cleaned and inspected prior to jointing.

When pipe laying is not in progress, the open ends of the pipe shall be closed by a suitable plug or cap to prevent the entrance of trench water, insects, rodents or other small animals, and other foreign materials.

**SECTION 751.9** (revised 2004) *Connections to asbestos-cement and other pipe materials:*

All connections between polyvinyl chloride (PVC) plastic pipe and asbestos-cement, cast iron, steel and other pipe materials shall be made in accordance with the manufacturer's recommendations using special adapters made for the type of connection involved.

**SECTION 751.10** (revised 2010) *Modify pressure and leakage test requirements:*

Hydrostatic pressure and leakage testing for PVC pipe shall be per applicable portions of M.A.G. Spec. 610.15 or as modified herein and shall be performed concurrently for a minimum of 2 hours, as directed by the Engineer. Allowable leakage shall be in U.S. Gallons per hour. The following formula shall be used:

$$L = 2 \frac{ND\sqrt{P}}{7400}$$

WHERE: L = Allowable leakage in Gallons per hour

N = Number of joints being tested

D = Nominal diameter of pipe in inches

P = Average observed test pressure of the pipe measured at the lowest end of test section, shall be a minimum of 200 psi for lines smaller than 16 inches and 150 psi for lines 16 inches or larger unless specified otherwise in the special provisions, plans or by the City of Kingman Engineering Representative.

**SECTION 751.11** (revised 2010) *Add to the end of last sentence:*

All Joint Restraint Systems shall be manufactured in accordance with ASTM, ANSI, and AWWA Standards. The Joint Restraint Systems designed and distributed by the Uni-Flange Corporation of Jacksonville, Florida are acceptable for use on C-900 and C-905 PVC pipe in the City of Kingman. Use of other manufacturer's brands requires prior approval from the Utilities Superintendent. Restraint devices for PVC pipe shall incorporate a series of

**CITY OF KINGMAN**  
**2012 ADDENDUM TO MAG STANDARD SPECIFICATIONS**

---

machined serrations (not "as cast") on the inside diameter of the ring to provide positive restraint, exact fit and 360 contact and support of the pipe wall. The use of Mega Lug type restraints is prohibited on PVC. Restraint devices shall be placed on the pipe at the locations specified by the Engineer.

**SECTION 765.3** (revised 2004)

The first sentence of MAG Section 756.3 is revised to read: "Fire hydrants shall be dry barrel of the manufacturer shown on the City of Kingman Standard Detail 360."